

TEST CERTIFICATE




The test results of the performed test series are given in the test reports
No. TE 213 02 40 from Euromold N.V.
and
No. 1569.0517.3.217 from IPH-Berlin

Requestor:	EUROMOLD NV ZUID III Industrielaan 12 B-9320 EREMBODEGEM
------------	---

TEST OBJECT	: Separable Tee-connector – Interface type C (EN 50180)
Type	: (P) 400TB/G
Rated voltage U_0/U	: 20.8/36 kV
Highest system voltage U_m	: 41.5 kV
Rated current	: 630 A
Manufacturer	: EUROMOLD N.V.
Cable reference	: N2XS2Y 1X185 RM/25mm ² – 18/30 (36)kV - AKH
Request number	: TRF 2002-28

Date of tests	Test specification
06/11/02 – 15/01/03	Cenelec HD 629.1 S1 (11/1996) + A1 (2001)
09/07/03 – 22/07/03	Cenelec HD 628 S1 (11/1996) + A1 (2001)
	Test series : Table 7, sequences D1 and D2

TEST RESULT: The test object successfully passed the prescribed test series.

EUROMOLD – ELAB Electrical testing laboratory		
Lab. Technician	Techn. responsible	Lab. Responsible Approval
 J. Cauwel	 Ing E. De Ridder	 Ir F. Claeys

Erembodegem, 22 December 2003