

CERTIFICATE

KEMA No.: 2084121.02

Issued to:
Applicant:

Nexans Benelux S.A.
Alsebergsesteenweg 2
1501 Buizingen
Belgium



Manufacturer/Licensee:
NEXANS BENELUX S.A.
Rue Benoit, 1
7370 Elouges (Dour)
Belgium

Product : cables for fixed wiring
Trade name : NEXANS
Type : EO-YMeKasz

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:


- a type test according to the standard KEMA 162-4:2007;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 936886

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: March 12, 2007 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.


P. Nabuurs
Managing director


H.R.M. Barends
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	cables for fixed wiring
trade name	:	NEXANS
type	:	EO-YMeKaszh
rated voltage	:	0,6/1 kV
conductors	:	class 1 or 2 for the cross-sections up to and including 10 mm ² . class 2 for the cross-sections form 10 mm ² and up.
insulations	:	XLPE compound
innersheath	:	PE compound
oversheath	:	PE compound
colour of oversheath	:	grey with green stripes
tested cables	:	4x2,5 mm ² and 3x16 mm ²
certified cables	:	2-5 x 1,5-25 mm ²

TESTS**Test requirements**

KEMA 162-1:2007
KEMA 162-2:2007
KEMA 162-4:2007

Test result

The test results are laid down in KEMA test file 2084121.02.

Conclusion

The examination proved that all test requirements were met.

Tested by : B. Vos

Checked by : A.A. Mackenbach

**Factory-Location**

Nexans Benelux S.A.
Alsembergsesteenweg 2
1501 Buizingen
Belgium